



PE PIPE DIMENSIONS				
TYPE	SIZE	STANDARD DIMENSION RATIO	MATERIAL	PRESSURE RATING
MAIN	250mm OD	SDR13.6	PE100	PN 12.5
MAIN	125mm OD			
RIDERMAIN	63mm OD	SDR11	PE80	
CONNECTION	25mm OD			

- NOTES:**
- LEVELS ARE IN TERMS OF THE MOTURIKI DATUM.
 - COORDINATES ARE IN TERMS OF BAY OF PLENTY 2000 CIRCUIT.
 - ORIGIN OF LEVELS TCC BENCHMARK BM 1142 RL 35.645m.
 - METHOD OF SURVEY: GPS
 - ALL WORKS WERE CARRIED OUT TO TCC IDC 2011 STANDARDS.
 - ALL RIDERMAINS ARE 63 OD PE UNLESS OTHERWISE SPECIFIED.
 - REFER TO TABLE FOR PE PIPE DETAILS
 - WHERE MULTIPLE WATER METERS ARE BANKED AT THE BOUNDARY 2 OR 3 WATER METERS HAVE BEEN PLACED IN EACH BOX.
 - NO VALVES OR HYDRANTS ARE LOCATED IN THE CARRIAGEWAY.
 - ALL WATER METERS HAVE BEEN INSTALLED WITHIN THE ROAD RESERVE EXCEPT FOR KISSLING TERRACE.

- LEGEND:**
- AS BUILT WATER MAIN
 - AS BUILT RIDER MAIN
 - AS BUILT HYDRANT
 - AS BUILT SLUICE VALVE
 - AS BUILT GATE VALVE
 - AS BUILT WATER METER

ORIGINATOR: PSJ	DATE: 06.06.18	SIGNED:	TRIS	ISO 9001 QUALITY ASSURED	<p>Summit THE LAKES (2012) LIMITED, TAURANGA</p>	<p>PROJECT: THE LAKES (2012) LIMITED, TAURANGA</p> <p>TITLE: STAGE 3JKL CIVILS WATER RETICULATION AS BUILT PLAN</p> <p>SHEET 3 TCC IP 101861</p>	ISSUE STATUS: FINAL AS BUILT	
DRAWN: PSJ	DATE: 06.06.18	SIGNED:	29.06.18	ASSOCIATION OF CONSULTING ENGINEERS NEW ZEALAND			PROJECT No: 1510-141209-01	SCALES: 1:625 - A1 1:1250 - A3
CHECKED: GPR	DATE: 27.06.18	SIGNED:		<p>TAURANGA OFFICE LEVEL 1, 60 SPRING STREET TAURANGA 3110 T +64 7 578 0023 W www.harrisonsgrison.com</p>	<p>PROJECT: THE LAKES (2012) LIMITED, TAURANGA</p> <p>TITLE: STAGE 3JKL CIVILS WATER RETICULATION AS BUILT PLAN</p> <p>SHEET 3 TCC IP 101861</p>	<p>DRAWING No: 141209-AB303</p>	<p>REV B</p>	
APPROVED: GPR	DATE: 27.06.18	SIGNED:						<p>REF REVISIONS</p>